

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1209:212 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174
Contact: *Trish Linhart (630) 377-6674 Fax (630) 377-7245

DESIGN: Models 2W-MOD maintenance module. Unit is intended to be connected to Models 2W-B and 2WT-B smoke detectors. The module can also be connected to compatible 2-wire, conventional smoke detectors, however, the maintenance trouble feature of the module cannot be utilized. Styles D and B initiating device circuit wiring methods are supported. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8.5-35 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units.

*Rev. 06-16-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 16, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**